



BEACON CITY COUNCIL

Resolution No. _____ of 2019

RESOLUTION AUTHORIZING A CHANGE ORDER FOR THE PHILLIPS STREET RECONSTRUCTION PROJECT

WHEREAS, during test pit excavations, the contractor found that the existing watermain was not where it had been marked in the field, but rather the watermain was located directly below and ran parallel with the existing 4" gas main with a separation of just over 6"; and

WHEREAS, based upon further investigation, it was found that the NYSDOT only extended the 8" ductile iron watermain approximately 39' into Phillips Street from the water valve located within NYS Route 9D (Wolcott Ave); and

WHEREAS, since the wet tap connection had to be relocated, the city engineer decided to relocate the wet tap to tap into the newly installed ductile iron pipe as to completely eliminate the asbestos-cement pipe (ACP) within Phillips Street.

NOW THEREFOR BE IT RESOLVED, that the City of Beacon City Council authorizes the Mayor or City Administrator to approve a change order in the amount of \$35,894.50 for the Philips Street Reconstruction project.

Resolution No. _____ of 2019			Date: June 17, 2019				
Amendments							
Not on roll call.			On roll call			2/3 Required	3/4 Required
Motion	Second	Council Member	Yes	No	Abstain	Reason	Absent
		Terry Nelson					
		John Rembert					
		Lee Kyriacou					
		George Mansfield					
		Jodi McCredo					
		Amber Grant					
		Mayor Randy Casale					
		Motion Carried					