

**John Stinemire, P.E.**  
Consulting Engineer  
15 Railroad Avenue- Suite 201 Kingston, New York 12401  
Telephone (845) 331-8806  
Fax (845) 331-4890

May 30, 2019

Mr. Joseph Buglino, RA  
Alfandre Architecture, PC  
231 Main Street Suite 201  
New Paltz, NY 12561

RE: Utility Cross Connections  
MOD Project, 184 Main Street  
Beacon, New York

Dear Joe:

On May 29, 2019 I inspected the exposed portions of the existing utilities at the above referenced site for potential cross connections.

There is one internal roof drain toward the rear of the roof. The roof drain exits on the north-east corner of the building and discharges to the ground surface near the rear of the building. There are no site drains and no sump pumps at this building.

I found no evidence of any illegal cross connections with the existing utilities at this site.

Should you have any questions, please contact me.

Very truly yours,

A handwritten signature in black ink, appearing to read "John Stinemire", written in a cursive style.

John Stinemire, P.E.  
Consulting Engineer