


Hudson Land Design
Professional Engineering, P.C.
174 Main Street
Beacon, NY 12508
p: 845.440.6926
f: 845.440.6637



Job 2 Cross St.
Sheet No. _____ of _____
Calculated by ESR date 10/28/19
Checked by _____ date _____
Scale _____
Task _____

Water Usage

Second floor - 1 bedroom residential 9 units

110 GPD / bedroom = 990 GPD

First floor - Retail

assume 4 stores w/ 2 employees each

Shopping Center

0.1 GPD / SF 4,270 SF = 427 GPD

15 GPD / employee 8 employees = 120 GPD

third/fourth floors

assume Office Building
15 GPD / employee

assume 1 employee 500 SF

10,480 SF → 21 employees = 315 GPD

Total 1,852 GPD